

Отчет о суточных параметрах
(01.09.2023 0:00:00 - 30.09.2023 0:00:00)

Объект: Пермь г, Самолетная ул, д. 46 (2.1 МКД УК "Уралмонтажстрой")

Прибор: ИМ2300 F-Z Заводской номер: LE193

Точка измерения: Узел 1; Ресурс: ТС

Схема измерений: Теплосчетчик с част. датчиками (ЗСВ)

| Дата | T1 | T2 | dt | Gm1 | Gm2 | Qm1 | Qm2 | % | Qt1 | tm1 | ts1 |
|------------|-------|-------|-------|--------|--------|------|------|-------|--------|-------|-------|
| | °C | °C | °C | т | т | т/ч | т/ч | | Гкал | ч | ч |
| 01.09.2023 | 65.81 | 49.99 | 15.82 | 23.86 | 24.55 | 0.99 | 1.02 | --- | 0.390 | 24.0 | 24.0 |
| 02.09.2023 | 65.26 | 50.11 | 15.16 | 25.83 | 26.62 | 1.08 | 1.11 | -3.01 | 0.390 | 24.0 | 24.0 |
| 03.09.2023 | 66.04 | 49.81 | 16.22 | 22.37 | 23.09 | 0.93 | 0.96 | -3.17 | 0.370 | 24.0 | 24.0 |
| 04.09.2023 | 63.74 | 46.89 | 16.86 | 21.36 | 22.05 | 0.86 | 0.88 | -3.18 | 0.380 | 24.0 | 24.0 |
| 05.09.2023 | 65.46 | 49.01 | 16.44 | 25.67 | 26.50 | 1.07 | 1.10 | -3.18 | 0.440 | 24.0 | 24.0 |
| 06.09.2023 | 66.47 | 48.53 | 17.95 | 21.51 | 22.21 | 0.90 | 0.93 | -3.20 | 0.400 | 24.0 | 24.0 |
| 07.09.2023 | 65.48 | 49.53 | 15.95 | 25.83 | 26.47 | 1.08 | 1.10 | -2.45 | 0.420 | 24.0 | 24.0 |
| 08.09.2023 | 65.12 | 50.75 | 14.36 | 25.71 | 26.23 | 1.07 | 1.09 | -2.00 | 0.380 | 24.0 | 24.0 |
| 09.09.2023 | 64.91 | 50.80 | 14.12 | 27.83 | 28.44 | 1.16 | 1.19 | -2.17 | 0.400 | 24.0 | 24.0 |
| 10.09.2023 | 64.85 | 51.31 | 13.55 | 28.09 | 28.81 | 1.17 | 1.20 | -2.53 | 0.390 | 24.0 | 24.0 |
| 11.09.2023 | 65.63 | 49.73 | 15.91 | 25.57 | 26.25 | 1.07 | 1.09 | -2.62 | 0.420 | 24.0 | 24.0 |
| 12.09.2023 | 65.25 | 50.15 | 15.10 | 26.35 | 27.08 | 1.10 | 1.13 | -2.73 | 0.410 | 24.0 | 24.0 |
| 13.09.2023 | 65.51 | 49.98 | 15.53 | 25.56 | 25.96 | 1.06 | 1.08 | -1.55 | 0.420 | 24.0 | 24.0 |
| 14.09.2023 | 65.96 | 49.65 | 16.31 | 23.32 | 23.96 | 0.97 | 1.00 | -2.71 | 0.390 | 24.0 | 24.0 |
| 15.09.2023 | 66.10 | 49.01 | 17.09 | 23.36 | 23.98 | 0.97 | 1.00 | -2.62 | 0.420 | 24.0 | 24.0 |
| 16.09.2023 | 65.76 | 49.23 | 16.53 | 24.76 | 25.42 | 1.03 | 1.06 | -2.63 | 0.420 | 24.0 | 24.0 |
| 17.09.2023 | 64.42 | 51.67 | 12.75 | 33.05 | 33.91 | 1.38 | 1.41 | -2.57 | 0.410 | 24.0 | 24.0 |
| 18.09.2023 | 65.07 | 50.80 | 14.28 | 26.57 | 27.28 | 1.11 | 1.14 | -2.64 | 0.380 | 24.0 | 24.0 |
| 19.09.2023 | 65.24 | 49.89 | 15.36 | 28.35 | 28.94 | 1.18 | 1.21 | -2.06 | 0.440 | 24.0 | 24.0 |
| 20.09.2023 | 65.18 | 50.97 | 14.21 | 31.93 | 32.72 | 1.33 | 1.36 | -2.44 | 0.460 | 24.0 | 24.0 |
| 21.09.2023 | 65.61 | 50.46 | 15.15 | 29.44 | 30.26 | 1.23 | 1.26 | -2.75 | 0.430 | 24.0 | 24.0 |
| 22.09.2023 | 66.34 | 48.84 | 17.50 | 23.12 | 23.71 | 0.96 | 0.99 | -2.52 | 0.420 | 24.0 | 24.0 |
| 23.09.2023 | 66.06 | 49.12 | 16.94 | 24.97 | 25.48 | 1.04 | 1.06 | -2.02 | 0.440 | 24.0 | 24.0 |
| 24.09.2023 | 65.98 | 48.64 | 17.34 | 25.75 | 26.59 | 1.07 | 1.11 | -3.21 | 0.470 | 24.0 | 24.0 |
| 25.09.2023 | 66.30 | 47.32 | 18.97 | 25.84 | 26.54 | 1.08 | 1.11 | -2.67 | 0.520 | 24.0 | 24.0 |
| 26.09.2023 | 65.98 | 40.69 | 25.28 | 31.68 | 32.20 | 1.32 | 1.34 | -1.63 | 0.860 | 24.0 | 24.0 |
| 27.09.2023 | 66.32 | 34.13 | 32.19 | 34.21 | 34.94 | 1.43 | 1.46 | -2.11 | 1.110 | 24.0 | 24.0 |
| 28.09.2023 | 65.52 | 35.34 | 30.17 | 39.28 | 40.01 | 1.64 | 1.67 | -1.84 | 1.170 | 24.0 | 24.0 |
| 29.09.2023 | 67.56 | 32.67 | 34.89 | 29.04 | 29.65 | 1.21 | 1.24 | -2.08 | 1.010 | 24.0 | 24.0 |
| 30.09.2023 | 66.45 | 34.02 | 32.43 | 35.74 | 36.48 | 1.49 | 1.52 | -2.05 | 1.150 | 24.0 | 24.0 |
| Средние: | 65.65 | 47.30 | 18.35 | --- | --- | 1.13 | 1.16 | -2.51 | --- | --- | --- |
| Итого: | --- | --- | --- | 815.95 | 836.33 | --- | --- | --- | 15.710 | 720.0 | 720.0 |

| Дата | Gm1 | Gm2 | Qt1 | tm1 | ts1 |
|------------|----------|----------|---------|---------|---------|
| | т | т | Гкал | ч | ч |
| 31.08.2023 | 32464.02 | 29958.63 | 971.990 | 13672.1 | 15012.0 |
| 30.09.2023 | 33279.97 | 30794.96 | 987.700 | 14392.1 | 15732.0 |
| Итого: | 815.95 | 836.33 | 15.710 | 720.0 | 720.0 |

Представитель абонента

Представитель энергоснабжающей организации