

Отчет о суточных параметрах
(01.12.2023 0:00:00 - 31.12.2023 0:00:00)

Объект: Пермь г, Самолетная ул, д. 46 (2.1 МКД УК "Уралмонтажстрой")

Прибор: ИМ2300 F-Z Заводской номер: LE193

Точка измерения: Узел 1; Ресурс: ТС

Схема измерений: Теплосчетчик с част. датчиками (ЗСВ)

| Дата | T1 | T2 | dt | Gm1 | Gm2 | Qm1 | Qm2 | % | Qt1 | tm1 | ts1 |
|------------|--------|-------|-------|---------|---------|------|------|-------|--------|-------|-------|
| | °C | °C | °C | т | т | т/ч | т/ч | | Гкал | ч | ч |
| 01.12.2023 | 77.43 | 42.23 | 35.20 | 62.76 | 63.58 | 2.61 | 2.65 | -1.30 | 2.210 | 24.0 | 24.0 |
| 02.12.2023 | 80.95 | 45.89 | 35.06 | 71.35 | 72.26 | 2.97 | 3.01 | -1.27 | 2.490 | 24.0 | 24.0 |
| 03.12.2023 | 83.36 | 47.59 | 35.77 | 74.08 | 74.92 | 3.09 | 3.12 | -1.13 | 2.640 | 24.0 | 24.0 |
| 04.12.2023 | 87.91 | 45.52 | 42.38 | 69.64 | 70.40 | 2.90 | 2.93 | -1.09 | 2.930 | 24.0 | 24.0 |
| 05.12.2023 | 87.24 | 47.91 | 39.33 | 70.69 | 71.49 | 2.95 | 2.98 | -1.13 | 2.790 | 24.0 | 24.0 |
| 06.12.2023 | 86.14 | 49.96 | 36.19 | 60.54 | 61.34 | 2.52 | 2.56 | -1.31 | 2.670 | 20.1 | 24.0 |
| 07.12.2023 | 107.67 | 59.21 | 48.47 | 79.65 | 80.83 | 3.32 | 3.37 | -1.47 | 3.870 | 24.0 | 24.0 |
| 08.12.2023 | 113.49 | 63.29 | 50.21 | 83.71 | 84.95 | 3.49 | 3.54 | -1.47 | 4.220 | 24.0 | 24.0 |
| 09.12.2023 | 109.69 | 65.30 | 44.39 | 102.65 | 104.00 | 4.11 | 4.16 | -1.31 | 4.770 | 24.0 | 24.0 |
| 10.12.2023 | 112.61 | 66.11 | 46.49 | 98.73 | 100.01 | 4.11 | 4.17 | -1.29 | 4.550 | 24.0 | 24.0 |
| 11.12.2023 | 111.06 | 56.47 | 54.58 | 69.77 | 70.79 | 2.91 | 2.95 | -1.45 | 3.820 | 24.0 | 24.0 |
| 12.12.2023 | 90.28 | 57.05 | 33.24 | 68.57 | 67.58 | 2.86 | 2.82 | 1.45 | 3.220 | 18.5 | 24.0 |
| 13.12.2023 | 110.44 | 62.17 | 48.27 | 91.24 | 92.61 | 3.80 | 3.86 | -1.49 | 4.400 | 24.0 | 24.0 |
| 14.12.2023 | 109.49 | 57.89 | 51.60 | 75.55 | 76.75 | 3.15 | 3.20 | -1.58 | 3.900 | 24.0 | 24.0 |
| 15.12.2023 | 102.83 | 59.16 | 43.67 | 90.68 | 92.01 | 3.78 | 3.83 | -1.46 | 3.930 | 24.0 | 24.0 |
| 16.12.2023 | 100.06 | 52.85 | 47.22 | 70.70 | 71.91 | 2.95 | 3.00 | -1.70 | 3.330 | 24.0 | 24.0 |
| 17.12.2023 | 93.78 | 54.15 | 39.62 | 83.24 | 84.70 | 3.47 | 3.53 | -1.74 | 3.300 | 24.0 | 24.0 |
| 18.12.2023 | 93.22 | 51.83 | 41.39 | 77.16 | 78.55 | 3.21 | 3.27 | -1.79 | 3.210 | 24.0 | 24.0 |
| 19.12.2023 | 78.06 | 46.49 | 31.58 | 66.13 | 67.16 | 2.76 | 2.80 | -1.55 | 2.470 | 18.9 | 24.0 |
| 20.12.2023 | 79.75 | 44.81 | 34.94 | 71.53 | 72.66 | 2.98 | 3.03 | -1.57 | 2.490 | 24.0 | 24.0 |
| 21.12.2023 | 73.76 | 43.79 | 29.97 | 75.59 | 76.74 | 3.15 | 3.20 | -1.51 | 2.260 | 24.0 | 24.0 |
| 22.12.2023 | 70.02 | 39.90 | 30.12 | 65.78 | 66.91 | 2.74 | 2.79 | -1.70 | 1.980 | 24.0 | 24.0 |
| 23.12.2023 | 70.50 | 39.22 | 31.28 | 59.78 | 60.87 | 2.49 | 2.54 | -1.81 | 1.880 | 24.0 | 24.0 |
| 24.12.2023 | 70.81 | 39.53 | 31.27 | 63.88 | 65.02 | 2.66 | 2.71 | -1.77 | 2.000 | 24.0 | 24.0 |
| 25.12.2023 | 74.80 | 41.16 | 33.63 | 68.66 | 69.81 | 2.86 | 2.91 | -1.66 | 2.300 | 24.0 | 24.0 |
| 26.12.2023 | 75.94 | 41.19 | 34.75 | 63.43 | 64.53 | 2.64 | 2.69 | -1.72 | 2.200 | 24.0 | 24.0 |
| 27.12.2023 | 76.54 | 42.08 | 34.45 | 62.69 | 63.78 | 2.61 | 2.66 | -1.72 | 2.160 | 24.0 | 24.0 |
| 28.12.2023 | 79.60 | 45.68 | 33.92 | 71.06 | 72.16 | 2.96 | 3.01 | -1.54 | 2.410 | 24.0 | 24.0 |
| 29.12.2023 | 87.32 | 48.61 | 38.71 | 70.51 | 71.60 | 2.94 | 2.98 | -1.53 | 2.730 | 24.0 | 24.0 |
| 30.12.2023 | 92.06 | 51.74 | 40.33 | 72.83 | 73.94 | 3.03 | 3.08 | -1.51 | 2.930 | 24.0 | 24.0 |
| 31.12.2023 | 98.99 | 54.15 | 44.83 | 74.42 | 75.47 | 3.10 | 3.14 | -1.40 | 3.340 | 24.0 | 24.0 |
| Средние: | 89.86 | 50.42 | 39.45 | --- | --- | 3.07 | 3.11 | -1.40 | --- | --- | --- |
| Итого: | --- | --- | --- | 2287.00 | 2319.33 | --- | --- | --- | 93.400 | 729.5 | 744.0 |

| Дата | Gm1 | Gm2 | Qt1 | tm1 | ts1 |
|------------|----------|----------|----------|---------|---------|
| | т | т | Гкал | ч | ч |
| 30.11.2023 | 36518.63 | 34084.47 | 1093.990 | 15856.0 | 17196.0 |
| 31.12.2023 | 38805.63 | 36403.80 | 1187.390 | 16585.6 | 17940.0 |
| Итого: | 2287.00 | 2319.33 | 93.400 | 729.5 | 744.0 |

Представитель абонента

Представитель энергоснабжающей организации