

Отчет о суточных параметрах
(01.03.2026 0:00:00 - 31.03.2026 0:00:00)

Объект: Пермский край, Пермь г, Самолетная ул, д. 46 (ООО "УК "КВАНТ")
Прибор: ИМ2300 F-Z Заводской номер: LE193
Точка измерения: Узел 1; Ресурс: TC

Схема измерений: Теплосчетчик с част. датчиками (ЗСВ)

Дата	T1	T2	dt	Gm1	Gm2	Qm1	Qm2	%	Qt1	tm1	ts1
	°C	°C	°C	т	т	т/ч	т/ч		Гкал	ч	ч
01.03.2026	93.21	54.52	38.69	85.73	85.61	3.57	3.57	0.14	3.300	24.0	24.0
02.03.2026	90.50	51.12	39.38	79.67	79.69	3.32	3.32	-0.03	3.110	24.0	24.0
03.03.2026	88.28	51.22	37.07	77.82	77.88	3.24	3.24	-0.08	2.890	24.0	24.0
04.03.2026	93.20	53.07	40.13	78.49	78.50	3.27	3.27	-0.01	3.150	24.0	24.0
05.03.2026	97.89	56.38	41.52	85.11	84.94	3.55	3.54	0.20	3.480	24.0	24.0
06.03.2026	99.92	56.27	43.65	80.01	79.93	3.33	3.33	0.10	3.460	24.0	24.0
07.03.2026	100.12	53.14	46.99	69.69	69.80	2.90	2.91	-0.16	3.210	24.0	24.0
08.03.2026	96.61	47.84	48.76	57.69	58.10	2.40	2.42	-0.71	2.800	24.0	24.0
09.03.2026	98.12	52.04	46.08	72.07	72.25	3.00	3.01	-0.25	3.300	24.0	24.0
10.03.2026	105.83	57.73	48.10	82.01	81.87	3.42	3.41	0.17	3.920	24.0	24.0
11.03.2026	104.82	54.61	50.21	68.72	68.84	2.86	2.87	-0.17	3.420	24.0	24.0
12.03.2026	88.72	48.70	40.02	67.05	67.29	2.79	2.80	-0.36	2.690	24.0	24.0
13.03.2026	52.13	30.81	21.33	38.15	38.43	1.59	1.60	-0.73	1.050	24.0	24.0
14.03.2026	58.49	37.81	20.68	70.29	70.18	2.93	2.92	0.16	1.770	24.0	24.0
15.03.2026	74.16	42.85	31.31	59.98	60.35	2.50	2.51	-0.61	1.880	24.0	24.0
16.03.2026	72.72	43.96	28.76	66.97	66.90	2.79	2.79	0.10	1.890	24.0	24.0
17.03.2026	71.23	44.44	26.79	65.47	65.64	2.73	2.73	-0.26	1.740	24.0	24.0
18.03.2026	72.06	44.15	27.91	64.22	64.18	2.68	2.67	0.06	1.780	24.0	24.0
19.03.2026	69.74	41.24	28.50	60.17	60.07	2.51	2.50	0.17	1.680	24.0	24.0
20.03.2026	49.46	31.77	17.69	40.72	40.69	1.70	1.70	0.07	0.850	24.0	24.0
21.03.2026	67.43	43.43	24.00	75.76	75.04	3.16	3.13	0.95	1.880	24.0	24.0
22.03.2026	69.43	46.31	23.12	81.66	80.95	3.40	3.37	0.87	1.880	24.0	24.0
23.03.2026	69.81	45.46	24.35	75.03	74.60	3.13	3.11	0.57	1.820	24.0	24.0
24.03.2026	69.28	45.93	23.35	73.21	72.86	3.05	3.04	0.48	1.690	24.0	24.0
25.03.2026	68.73	45.91	22.83	77.37	76.93	3.22	3.21	0.57	1.750	24.0	24.0
26.03.2026	66.59	48.14	18.46	91.82	91.06	3.83	3.79	0.83	1.680	24.0	24.0
27.03.2026	67.01	47.63	19.38	88.83	88.14	3.70	3.67	0.78	1.700	24.0	24.0
28.03.2026	67.16	47.92	19.24	86.78	86.11	3.62	3.59	0.78	1.650	24.0	24.0
29.03.2026	68.23	46.47	21.76	75.60	75.16	3.15	3.13	0.58	1.630	24.0	24.0
30.03.2026	67.24	47.63	19.62	87.66	86.92	3.65	3.62	0.85	1.690	24.0	24.0
31.03.2026	67.02	47.68	19.33	84.47	83.83	3.52	3.49	0.76	1.610	24.0	24.0
Средние:	78.23	47.30	30.93	---	---	3.05	3.04	0.19	---	---	---
Итого:	---	---	---	2268.22	2262.74	---	---	---	70.350	743.9	744.0

Дата	Gm1	Gm2	Qt1	tm1	ts1
	т	т	Гкал	ч	ч
28.02.2026	12684.93	13465.61	413.820	4574.3	4955.7
31.03.2026	14953.15	15728.35	484.170	5318.2	5699.7
Итого:	2268.22	2262.74	70.350	744.0	744.0

Представитель абонента

Представитель энергоснабжающей организации